

# Annexure C

## PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 162/163

Dated: 25/1/25

It is certified that an inspection team headed by DR. SANGEETA M. RAO

(Name of Officers with designation) from PHC: HIRESAVALGI PHED

inspected the RASHTROTTHANA VIDYA KENDRA SHARANSIRASAGI

(Name & Address of the school) on 25/1/25 (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. 162, 163 dated 25/1/25

of 2 Borewells (PHED Lab) certified that the

RASHTROTTHANA VIDYA KENDRA (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the

hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.


This certificate is valid till one year

Signature with Seal: DR. SANGEETA  
Name : DR. SANGEETA  
Designation : AMO  
Name & Address of the Office / Department :

ಜಿಲ್ಲಾ ಆರೋಗ್ಯ ಇಲಾಖೆ  
ಕಾರ್ಯಾಲಯ  
ಬೆಂಗಳೂರು

To RASHTROTTHANA VIDYA KENDRA SHARANSIRASAGI (Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies



AUTONOMOUS  
INSTITUTION

AFFILIATED TO VTU BELAGAVI &  
APPROVED BY AICTE  
ACCREDITED BY NBA NEW DELHI

Hyderabad Karnataka Education Society's

# Poojya Doddappa Appa College of Engineering

KALBURGI - 585 102 - KARNATAKA - INDIA

ಹೈದರಾಬಾದ ಕರ್ನಾಟಕ ಶಿಕ್ಷಣ ಸಂಸ್ಥೆಯ

ಪೂಜ್ಯ ದೊಡ್ಡಪ್ಪ ಅಪ್ಪ  
ಕಾಲೇಜ್ ಆಫ್ ಇಂಜಿನಿಯರಿಂಗ್

ಕಲಬುರಗಿ - ೫೮೫ ೧೦೨ - ಕರ್ನಾಟಕ

Phone : 08472-2224360-220019-220349 - Offi.: 220172 - Resi.: 228479 - Fax : 255685  
Email : principal@pdaengg.com - principalpda@yahoo.com - Website : www.pdaengg.com

PDACEK/CED/TEST/2024/SS

To,  
Rashtrorothana Vidya Kendra  
Kalaburagi

Date: 03.12.2024

Sir,  
Sub: Test results of Water samples supplied by you reg.  
Ref: Your Letter No: NIL/Dated: 26-11-2024  
Rec. No: U76451/2024-25/ Date: 26.11.24/Rs.4500/-

With reference to above-cited subject, Test results of water sample supplied by you are as follows

Sl. No.	Parameter	Results of Water					As per IS 10500: 1991 Drinking water specification	
		Filter mission Sample No:1	Filter mission Sample No:2	Borewell Sample No:1	Borewell Sample No:2	Borewell Sample No:3	Requirement (Desirable limits)	Permissible limits (if no alternative source)
1	Total Hardness as $\text{CaCO}_3$	240 mg/l	180 mg/l	320 mg/l	420 mg/l	440 mg/l	300 mg/l	600 mg/l
2	Chlorides	36.07 mg/l	36.07 mg/l	92.17 mg/l	114 mg/l	122.23 mg/l	250 mg/l	1000 mg/l
3	pH	7.4	7.2	7.2	7.3	7.4	6.5 to 8.5	No relaxation
4	Calcium Hardness as $\text{CaCO}_3$	180 mg/l	90 mg/l	200 mg/l	260 mg/l	280 mg/l	75 mg/l	200 mg/l
5	Magnesium Hardness	40 mg/l	90 mg/l	120 mg/l	160 mg/l	160 mg/l	30 mg/l	100 mg/l
6	Alkalinity as $\text{CaCO}_3$	48 mg/l	60 mg/l	76 mg/l	112 mg/l	108 mg/l	200 mg/l	600 mg/l
7	TDS	200 mg/l	280 mg/l	480 mg/l	750 mg/l	430 mg/l	---	---
8	Turbidity	6.3 NTU	7.3 NTU	7.2 NTU	6.8 NTU	6.9 NTU	5 NTU	10 NTU
9	Fluoride	0.8 mg/l	0.6 mg/l	1.5 mg/l	0.8 mg/l	1.2 mg/l	0.5 mg/l	1.5 mg/l

This is for your kind information.  
Thanking you.

The Principal  
Rashtrorothana Vidya Kendra  
Sy. No. 243, Deval Ghangapur Road,  
Sharanasirasagi, Kalaburagi-585 103.

CORRESPONDENT

Rashtrorothana Vidya Kendra  
Sy. No. 243, Deval Ganapur Road,  
Sharanasirasagi, Kalaburagi-585103

Yours faithfully

Principal